



MM600

Micro-Ohm Meter Self Powered 600A Test Current

Micro-Ohm Meter

MM600

Introduction

In response to ever growing demands for safer and more accurate methods of testing circuit breakers, Weis has developed the MM600 portable micro-ohm meter with **self powered** test current. It is used for measurement of resistance $(\mu\Omega)$ by injecting a heavy current through a breaker contact or load carrying joint.

A high current pulsed output (typically 600A DC) allows for testing of the latest arcing and main contacts that require 500-600A to determine the difference between them, as well as to see if they are able to carry such a current.

As a stand-alone unit, static testing can be performed with a direct readout on a built in LCD meter. When used in conjunction with the Weis SA100, SA100R or SA100Rs switchgear analyser / breaker tester (having a travel input for breaker mechanism movement), a dynamic micro-ohm test (DRM / DCRM) can be made that will give detailed information about the state of fixed contact surfaces, moving contact surfaces, main contact, arcing contact and the complete current circuit of the breaker in every

step during a close-open operation.

Technical Specification

MEASUREMENT OUTPUT

Limited to 750A DC, typically 600A Current:

DC, dependant on loop impedance.

No-Load Voltage: 10V DC maximum.

Operation: Pulse with 1 second duration.

Safety: Re-settable thermal / magnetic circuit

Connectors: Heavy duty wing-nut.

MEASUREMENT INPUT

Range: 0 to $199.9\mu\Omega$ or $1999\mu\Omega$. Resolution: 0.1 or $1\mu\Omega$ (range selected).

0.25% of full-scale + 1% of reading

Voltage Sense: 1 x voltage input from contact / joint.

Connectors: 4mm safety socket.

OUTPUTS

Analogue: 2 x conditioned outputs representing

measured Current Level and Micro-Ohms (SA100 / SA100R / SA100RS

required).

1 x Calibrate for calibration check.

Connectors: 4mm safety socket.

GENERAL SYSTEM

Back-lit $3\frac{1}{2}$ digit LCD for readout of $\mu\Omega$ or Amps.

Current On lamp indication (red). Unit Armed lamp indication (green).

Trigger In (volt free contact) for Dynamic Micro-Ohm Test (SA100 / SA100R / SA100Rs required) and Trigger Out

'Operate' push button for 600A pulse mode of operation. Rotary Mode selector switch for Off / $199.9\mu\Omega$ / $1999\mu\Omega$. LED indicators: Fault, Over Current, Battery Low and

Multipurpose accessory socket for in-car charging, remote meter, power out, trigger in and trigger out.

OPERATING VOLTAGES

Test Current: Internal sealed rechargeable batteries. Operation and: 110 to 330V DC or 85 to 265V AC

Recharge Power (47 to 440Hz) auto-sensing.

In-Car 12V DC @ 3A (negative earth).

<100VA load. Burden:

ENVIRONMENTAL

Operating

-20°C to 70°C (-4°F to 158°F). Temperature: 0 to 97% RH non-condensing. **Humidity:**

2kV rms for 1 minute (input / output to Isolation:

ground).

Surge Withstand

Transient: To IEC 801-5. 5kV, 1.2/50μSec, 0.5

Common Mode: Severity level class 4. Series Mode: Severity level class 3.

To IEC 801-3 level 3. RF Immunity:

10V/m 26-1000MHz.

Emissions: To EN50081-1: 1992.

MECHANICAL DETAILS

Case: Reinforced aluminium, 370mm wide x

185mm deep x 350mm high.

Weight: <10kg.

SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE

HEAD OFFICE WEIS GMBH & Co. KG

Kaffeestrasse 4 28779 Bremen Germany

+49 (0) 421 606040 +49 (0) 421 607066

Email: WeisGmbHBremen@t-online.de



UK OFFICE WEIS GMBH & Co. KG

'Bay Trees' 47 Beltinge Road Herne Bay

Kent CT6 6DA UK

Tel: +44 (0) 1227 749413 Email: sales@WeisGmbH.net